



NOTES:

1. LIFT STATION SITE FOR NON-DRIVEWAY ACCESS TO A STREET.
2. DIMENSIONS A AND B WILL VARY ACCORDING TO THE SIZES OF THE WETWELL, PUMPS, AND DISCHARGE PIPING. MINIMUM SIZE SHALL BE: A=15', B=20'. DIMENSION C=1' IN HORIZONTAL FOR 1' OF DEPTH OF WETWELL MEASURED RADIALLY FROM THE CENTER (MIN.) IN ALL DIRECTIONS.
3. THE SLOPE OF THE CONCRETE APRON SHALL BE BETWEEN 2% AND 10%. THE DESIGN SHALL PREVENT STORMWATER FROM ENTERING THE LIFT STATION SITE.
4. FINAL LIFT STATION SITE PLANS SHALL BE APPROVED BY THE UTILITIES MANAGER.

NON DRIVEWAY PUMP STATION SITE PLAN